



Daily Field Report

Bolts in Epoxy
 Bolts in New Concrete
 Concrete
 Dowels
 Fireproofing
 Holdowns
 Masonry
 Post Tensioned Concrete
 Pull Test
 Rebar
 Roof Nailing
 Shear Walls
 Shotcrete
 Torque Test

Job Address:

870 El Camino Del Mar

San Francisco, CA

Permit(s):

2018.05.23.9894

Date of Inspection: 02/14/22

Brandon Burdine reported to Guillermo with

at jobsite.

Observed placement of:

☐ Concrete ☐ Shotcrete ☐ Rebar ☐ Other:
For: ☐ Columns ☐ Footing ☐ Grade Beam☐ Mat Slab ☐ Piers ☐ Piles ☐ Post Footing☐ PT Deck ☐ Retaining Walls ☐ SOG ☐ Stairs☐ Stem Wall ☐ Underpinning ☐ Wall☐ Other: _____ at the following location(s):

Monitored mix #, slump, temperature, and time limit. Prepared test

☐ Cylinders ☐ Panels ☐ Other: _____Sampled from ☐ Truck Chute ☐ Nozzle ☐ Other: _____

Strength tested at 28 days. Supplier: _____

Location(s) sampled: _____

Total Number Of Sets: 0 Total Number of Samples: 0

Design	Set #1	Set #2	Set #3	Set #4
PSI				
Agg. Size				
Slump				
Field				
# per set				
Mix#				
Mix PSI				
Agg. Size				
Compliant	<input type="radio"/> Y <input type="radio"/> N	<input type="radio"/> Y <input type="radio"/> N	<input type="radio"/> Y <input type="radio"/> N	<input type="radio"/> Y <input type="radio"/> N
Slump				
Mix Temp				
Air Temp				
Total Yds				
Truck #				

Field

per set

Mix#

Mix PSI

Agg. Size

Compliant ☐ Y ☐ N ☐ Y ☐ N ☐ Y ☐ N ☐ Y ☐ N

Slump

Mix Temp

Air Temp

Total Yds

Truck #

Observed placement of ☐ Bolts in new concrete ☒ Epoxy Bolts ☐ Epoxy Dowels ☐ Other:

For: Footing tie-ins.

#5 rebar, 8" embedment, 3/4" drill bit

Per 7/S5.02 at (4-6, F) on page S2.01

Epoxy Type: Hilti Hit-RE 500 V3

Exp. Date: 8/1/22

Cleaned: YES ☒ NO ☐

Performed

on

To the following specified tensions:

☒ Work was observed was, to the best of Brandon Burdine's knowledge, in conformance with approved plans, specifications, and application standards of workmanship. If present, any exceptions or non-compliance conditions were brought to the attention of _____ for corrective action, and are as follows:

See attached non-compliance report. Contractor's acknowledgment of receipt: _____

NORCON, LLC. SPECIAL INSPECTION AND TESTING LABS

470 3rd Street, Suite 105 | San Francisco, CA 94107 | Phone: (415) 692-0519 | Email: info@norcon415.com