



Pre-Construction Test Panel Core Grading

April 4, 2022

Job Name: 870 El Camino Del Mar
San Francisco
Application #: 2018-05-23-9894, 2021-11-12-2309
Suskind Thompson Construction

Date of Inspection

March 11th, 2022

Nick Toby reported to Guillermo at 870 El Camino Del Mar to observe the rebar placement for a pre-construction test panel. The panel was constructed based on the approved drawings and is a direct representation of the the retaining wall rebar @ (A-G, 2-4) @ level 1 foundation & floor framing plan (1/S2.01) as per detail 10/S5.02 - #5 vert. @ 12" O.C. E.F. & #4 horizon. @ 16 O.C. E.F. on 8 @ C of the foundation plan on page S2.1, detail 1/S3.1 & 12/S3.2. The reinforcement was in general compliance with the approved plans.

The following nozzle man/men were present to shoot the panel.

#1 Nemesio Gonzalez	#2 Roberto Mariscal
Certification # 02072460	Certification # 00073323
Expiration date: 7-16-2022	Expiration date:

The panel was marked horizontally into two sections, nozzleman #1 shot the bottom half and nozzleman 2 the top.



March 11th, 2022

Norcon reported to 870 El Camino Del Mar to core the pre-construction test panel shot on 2-22-22.