



Liquid & Plastic Limits



	MATERIAL DESCRIPTION	LL	PL	PI	%<#40	%<#200	USCS
●	Brown Sandy Lean CLAY	37	17	20			

● Source: B-2

Sample No.: Bag #9

Elev./Depth: 3.0'

LAWRENCE B. KARP
CONSULTING
GEOTECHNICAL ENGINEER
100 TRES MESAS
ORINDA, CALIFORNIA 94563
(925) 254-1222

PLASTICITY

University Condominiums
1122 University Avenue, Berkeley

DATE
January 2004

PROJECT
204016

FIGURE: **D**